

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 262

Dated: 23.11.23

It is certified that an inspection team headed by En. Susmita Simalw, Asst. Executive Engineer
(Name of Officers with designation) from RWSS Sub-division, Aska
(Name of Department/ Office) inspected the Aryan Public School, Kalesandhapur, Aska
(Name & Address of the school) on 22.11.23 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 03 years.

Signature with Seal: Assistant Executive Engineer

Name : SUSMITA SIMALW

Designation : Asst. Executive Engineer

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

RWSS Sub-division, Aska
(Gangam).

To

The Principal

Aryan Public School,
Kalesandhapur, Aska (Gangam).
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

RWS&S SUB DIVISIONAL LABORATORY, ASKA

Date of Sample collection- 14.11.23

Date of Testing at SDLL, Aska- 15.11.23

Sl No.	Name of Block.	Name of the G.P	Name of the village	Name of the habitaion	Location	Tested Parameters						
						PH	Alkalinity as CaCO3 Mg/Ltr	Total Hardness as CaCO3 Mg/Ltr	Cl Mg/L	TDS Mg/Ltr	E.C.in uscm	Turbi dity(N TU)
Acceptable limit as per IS-105000:2012						6.5	200	200	250	500		1.0
Permissible limit in the absence of alternative soure as per IS-10500:2012						8.5	600	600	1000	2000		5.0
1	Aska	kalasandhapur	kalasandhapur	proper	Aryan public school	7.2	86	88	74	298	420	0.79

N.B :

1 Bacteria are absent by H2S test strips .

Shrawan Jais' Adhikari

Lab. Chemist
RWS&S Sub-Dision, Aska