

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 52

Dated: 11/04/25

It is certified that an inspection team headed by Er. Chinnoyi K. Raut, Asst. Eng.
(Name of Officers with designation) from RWS&E Sub-Division, PHED Aska Engineer

inspected the Aryan Public School, Kalasandhapur, Aska

(Name & Address of the school) on 11/04/25 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. - dated 10/04/25

of RWS&E Sub-Division (PHED Lab) certified that the
Aryan Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 03 years

Signature with Seal: [Signature] 11/04/25
Name: Chinnoyi K. Raut
Designation: Asst. Executive Engineer
Name & Address of the Office / Department: RWS&E Sub-Division, Aska
Assistant Executive Engineer
RWS&E Sub-Division Aska (Gm)

To The Principal
Aryan Public School, Kalasandhapur, Aska
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature]
Manager
Aryan Public School

[Signature]
PRINCIPAL
Aryan Public School
Kalasandhapur,
Aska (Ganjam)


Sub Divisional Water Testing Laboratory Aska

Source Details		
1.	Type of Source- Deep Tube well	Date of Sample Collection :- 09/04/2025 Date of testing :- 10/04/2025
2.	Location & Address of Sampling Point- (Aryan Public School)	
3.	Longitude- Latitude-	Name of Village- Kalasandhapur Habitation- Proper
4.	Name of G.P- Kalasandhapur	Name of Block- Aska Name of District - Ganjam

Water Quality Results-

Sl No	Water Quality Parameters	BIS		Value (mg/L)	Contamination (Yes) (No)	
		Acceptable Limit	Permissible Limit			
1	pH	6.5-8.5	6.5-8.5	7.0		NO
2	Alkalinity	200 mg/L	600 mg/L	88		NO
3	Chloride	250 mg/L	1000 mg/L	298		NO
4	Hardness	200 mg/L	600 mg/L	90		NO
5	TDS (Total Dissolved Solids)	500 mg/L	2000 mg/L	571.2		NO
6	Conductivity		1000 mho/cm	878.7		NO
7	Turbidity	1 NTU	5 NTU	0.4		NO
8	(H ₂ S Test)			Negative		NO


 Manager
 Aryan Public School


 Mahendra Bhuyan
 Laboratory Assistant
 RWS&S SubDivision, Aska
 10.04.2025



PRINCIPAL
 Aryan Public School
 Kalasandhapur,
 Aska (Ganjam)